

| | | | | | | |
|--|--|--|--|---|------------------|----------------------|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | | 1. CONTRACT ID CODE DTFANM-13-R-00034 | PAGE 1 | OF PAGES 3 |
| 2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 004 | | 3. EFFECTIVE DATE 12/17/2012 | | 4. REQUISITION/PURCHASE REQ. NO. | | |
| | | | | 5. PROJECT NO. (If applicable) PASCO HVAC | | |
| 6. ISSUED BY GINA STORLIE, AAQ-530 1601 Lind Ave SW Renton, WA 98057 | | | | 7. ADMINISTERED BY (If other than Item 6) | | |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) | | | | <input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. DTFANM-13-R-00025 9B. DATED (SEE ITEM 11) 11/20/2012 | | |
| | | | | <input type="checkbox"/> 10A. MODIFICATION OF CONTRACT/ORDER NO. | | |
| | | | | 10B. DATED (SEE ITEM 13) | | |
| *TO BE COMPLETED BY VENDOR IF NOT COMPLETE CODE | | | | FACILITY CODE | | |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | | | | |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer is <input type="checkbox"/> extended <input checked="" type="checkbox"/> is not extended. | | | | | | |
| Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation on as amended, by one of the following methods: | | | | | | |
| (a) By completing Item 8 and 15, and returning <u>1</u> copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified. | | | | | | |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required) | | | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14. | | | | | | |
| <input type="checkbox"/> A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A. | | | | | | |
| <input type="checkbox"/> B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14, | | | | | | |
| <input type="checkbox"/> C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | | | | | | |
| <input type="checkbox"/> D. OTHER (Specify type of modification and authority) | | | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office. | | | | | | |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) PLEASE FIND ATTACHED ANSWERS TO QUESTIONS SUBMITTED | | | | | | |
| | | | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect. | | | | | | |
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) GINA V STORLIE | | |
| 15B. CONTRACTOR/OFFEROR | | 15C. DATE SIGNED | | 16B. UNITED STATES OF AMERICA | | 16C. DATE SIGNED |
| _____ (Signature of person authorized to sign) | | | | BY _____ (Signature of Contracting Officer) | | |

Amendment No. 004
DTFANM-13-R-00025
Answers to Questions Submitted

QUESTION:

Is AHU-1 a unit that the FAA has already purchased (is it GFE)?

ANSWER: No

QUESTION: Capacity of the electric heat required?

ANSWER: Electric Heat – Contractor shall provide **A 17 KW electric coil.** Contractor shall ensure airflow across coil is sufficient for heater size.

QUESTION: Is the unit to sit on a new roof curb or an existing curb?

ANSWER: Existing Curb is detailed in the drawings. It is the contractors responsibility to create a transition to which the units can be mounted, both for structural attachment, and for external flashing from roof surface up to unit.



Other Unit2.pdf



Other Unit1.pdf



Unit View.pdf

QUESTION: If existing, the model number of that older unit?

ANSWER: Existing Unit appears to have had nameplate information removed. Performance information is indicated in equipment schedule in drawing package. Specifications detail that new unit's capacity is to be 3 tons.

QUESTION: Existing units are heat pumps, yet your spec requests an air conditioner, is this correct?

ANSWER: Yes. Units shall be standard AC units, not heat pumps.

QUESTION:

In the specs is says to have the electric heater in the rooftop unit, So are we not going to use the duct heater ?

ANSWER:

Electric heater is to be provided in rooftop unit. The existing duct heater is on a duct that only provides air on the BACKUP unit. Its a different system.

QUESTION:

Also says to supply spare parts. Do you want all of the parts listed?

ANSWER:

All of the Materials listed in Section 23 74 13 - Section 1.7 - Extra Materials are to be provided. If the new unit ends up not being belt driven, the spare fan belts may be omitted.

Unit to be replaced

Curb under unit to remain. Contractors responsibility to modify curb or create structural transitions. New Penetrations to be avoided. External flashing to be provided around new curb transition to weatherproof area under the unit.

Unused Condenser to be removed and all connections piping.

Base flashing and counterflashing to be replaced and made weatherproof.

06 06 2012



06 06 2012

Another example on the roof of a transition created for a replacement unit with a footprint different than that of the original. Similar clean look expected.



Similar situation on the roof where transition was custom built and old curb area was enclosed.

12 06 2011